

## ROCKY FLATS ENVIRONMENTAL TECHNOLOGY SITE REGULATORY CONTACT RECORD

---

**Date/Time:** August 11, 2004 / 0900

**Site Contact(s):** Dyan Foss  
**Phone:** 303-966-7577

**Regulatory Contact:** Edd Kray  
**Phone:** 303-966-2115

**Agency:** CDPHE

---

**Purpose of Contact:** Disposition of Building 711

---

### Discussion

Building 711 is a cooling tower that supplied the cooling systems in Building 707, 708, and 750. The cooling tower was constructed in 1982 and is a three cell induced draft cross-flow cooling tower supplied by a ten inch firewater feeder. The cooling tower was designated a Type 1 facility in the Reconnaissance-Level Characterization Report (RLCR) for the Building 707 Cluster, Revision 1, dated August 1, 2000.

The RLCR involved a review of historical information, chemical sampling, and radiological surveys, which are summarized in Appendix E of the RLCR. Based on all of the information collected during the RLCR, no contamination was identified. In accordance with the 707 DOP, Type 1 decommissioning may be performed using RFETS procedures upon notification to the LRA.

The demolition of this structure was discussed with the CDPHE 707 Building representative, and he concurred with the approach to initiate demolition. Surveys will be conducted during the demolition activity as necessary for waste disposition.

---

**Contact Record Prepared By:** Dyan Foss

---

### Required Distribution:

M. Aguilar, USEPA  
S. Bell, DOE-RFPO  
B. Birk, DOE-RFPO  
C. Deck, K-H Legal  
D. Foss, K-H 707/776/777  
S. Garcia, USEPA  
C. Gilbreath, K-H 771/774


R. Leitner, K-H 371/374  
J. Mead, K-H ESS  
G. Morgan, DOE-RFPO  
S. Nesta, K-H RISS  
K. North, K-H ESS/MS  
R. Schassburger, DOE-RFPO  
D. Shelton, K-H ESS

### Additional Distribution:

Gary Schuetz  
Bruce Wallin  
David DelVecchio  
Bob Kury  
Mike Grube  
Victoria Wren

---

Contact Record 4/10/00  
Rev. 5/24/04



S. Gunderson, CDPHE  
J. Legare, DOE-RFPO

C. Zahm, K-H Legal

---

---